



Approvals

PO BOX 15007, AJMAN, UAE
TEL: +97167436665, +971506287115
FAX: +97167437033,
Email: info@vulcanuae.com



PO BOX 117478, DUBAI, UAE
TEL: +97142579811, +971507460465
FAX: +97167437033
Email: info@vulcanuae.com



KAHRA MAA المؤسسة العامة القطرية للكهرباء والماء
Qatar General Electricity & Water Corporation

اللجنة الفنية لمتطلبات السلامة
Safety Technical Committee

Ref. No.: HSE/1251/ 2013
Date: 15 / 04 / 2013

Subject: Prequalification with Kahramaa for Fire Rated Steel Door

We refer to your letter **BQ/KAHRAMAA/035/2012** dated 21.10.2012 enclosing the submittals for prequalification of "Vulcan fire rated steel doors" with Kahramaa. After reviewing the documents, Kahramaa Safety Committee hereby grants approval to Vulcan Industries LLC manufactured fire rated steel doors with below specifications;

Fire Rated Steel Door Types

1. Vulcan Single & Double Steel Flush Doors Set
2. Vulcan Single & Double Vision Door Set
3. Vulcan Single Steel Transom Panel Door Set
4. Vulcan Double Steel Transom Panel Door Set
5. Vulcan Single Steel Side Transom Door Set
6. Vulcan Double Steel Side Transom Door Set

Door Specifications:

Single / pair of swinging steel stiffened hollow metal type fire doors intended for 3 hours

Door Sizes = 2200 mm (Width) X 2400 mm (Height)

2400 mm can be over-panel (Transom panel) and over the width of 2200 mm can be Side Panel which should not be more than the width of single shutter size

Ironmongery / Hardware Details:

- 1.5 Hot deep galvanized sheet used for frame supply by Jindal / AlGurail
- 1.2mm Hot deep galvanized sheet used for leaf supplied by Jindal / AlGurail
- 3mm mild steel used for reinforcement supplied by Gentex
- Honeycomb 0.43mm thick, 32mm cell size used inside the door, insulation material supplied by honeycell



Tel: (+974) 44845577/5575 • Fax: (+974) 44845595 • P.O. Box: 41 Doha - Qatar

www.km.com.qa | better living | ليهاذا أفضل

PO BOX 15007, AJMAN, UAE
TEL: +97167436665, +971506287115
FAX: +97167437033,
Email: info@vulcanuae.com



PO BOX 117478, DUBAI, UAE
TEL: +97142579811, +971507460465
FAX: +97167437033
Email: info@vulcanuae.com



KAHRAMAA المؤسسة العامة للكهرباء والماء
Qatar General Electricity & Water Corporation

اللجنة الفنية لمتطلبات السلامة
Safety Technical Committee


SR. NO	HARDWARE	BRAND	CODE
1	Hinges (102 x 102 x 3 mm)	Devon	89339.86
2	Mortise Latch Lock	Consort	CH 7251F
3	Solid Lever Handle	Consort	CH900
4	Flush Bolt	Consort	CH2820.8 & 9
5	Dust Excluding Socket	Consort	CDS.75
6	Double Profile Cylinder	Consort	CH780.2
7	Push Bar	Consort	CPH6080E
8	External Access Device	Consort	CP649

Please note that KAHRAMAA Safety Committee approval is only for above mentioned fire rated steel doors with specified hardware and is valid for 2 years from date of approval letter. Any noncompliance to specifications or information submitted during prequalification may lead to automatic withdrawal of this approval and disqualification of the company.

Regards,

Eng. A. Rahman Ali Al Naama
Head of Safety Technical Committee
KAHRAMAA

Initial:



Tel: (+974) 44845577/5575 - Fax: (+974) 44845595 - P.O. Box: 41, Doha - Qatar

www.km.com.qa better living

PO BOX 15007, AJMAN, UAE
TEL: +97167436665, +971506287115
FAX: +97167437033,
Email: info@vulcanuae.com



PO BOX 117478, DUBAI, UAE
TEL: +97142579811, +971507460465
FAX: +97167437033
Email: info@vulcanuae.com



Classified
Fire Rated Steel Doors



بسم الله الرحمن الرحيم

State of Qatar
Ministry of Interior
General Admin. of Civil Defence

شهادة عدم مطابقة

الإشادة رقم ٢٠٠٩/١٠/٩
التاريخ ٢٠٠٩/١٠/٩

Raf :
Date :

لا مانع لدى الإدارة العامة للدفاع المدني من قيام:

والتي تعمل المجلس التجاري رقم (٣٠٨٩٠) الصادر من إدارة الشؤون التجارية - قسم المجلس التجاري بوزارة الأعمال والتجارة بتاريخ ٢٠٠٥/٠٦/٢١ ومصابيح نفاية ٢٠١٠/٠٦/٢١ من استيراد وتسويق:-

**SWINGING TYPE FIRE DOOR
FIRE DOOR AND WINDOW FRAMES**

المصنعة في الإمارات :-

Vulcan Industries LLC

وذلك حسب النوصيات التالية :-

SWINGING TYPE FIRE DOOR

- 2Hrs Single or Pair with Astragal (Single point lock/ flush bolt)
- 2Hrs Single Rim / Mortise Fire Exit Hardware
- 2Hrs Pair with Astragal (Vertical Rod / Vertical Rod Fire)

FIRE DOOR AND WINDOW FRAMES

- Door Frames for use as a components in fire door assemblies that meet the requirements of UL 10B

وبما أنها مطابقة للمواصفات الفنية العالية التالية :-

UL

فانه لا مانع لدينا من استيرادها وتسويقها في المنشآت الصناعية والسكنية والتجارية بالدولة شريطة مراعاة ما يلي:-
مراجعة إدارة الوقاية بالإدارة العامة للدفاع المدني في حالات الاستيراد ليتم التأكد من مطابقتها للمواصفات الفنية العالية التي تمت بموجبها الموافقة عليها.
أن يحمل المنتج علامة الجودة (UL)

أعطيت هذه الشهادة بناءً على طلب الشركة المذكورة أعلاه دون أدنى مسؤولية على الإدارة العامة للدفاع المدني

الدولة قطر
State of Qatar
الدولة قطر
State of Qatar

هذه الشهادة صالحة لمدة سنتين من تاريخ الإصدار

ملاحظة: يعنى للإدارة العامة للدفاع المدني أن توقف استيراد وتسويق هذا المنتج في أي وقت متى ما أثبتت الأبحاث والدراسات والتجارب التي تجري من قبل المنظمات والمراكز العالمية والعامة في هذا المجال عدم كفاءتها للاستخدام.

نسخة: السيد / مدير عام الإدارة العامة للدفاع المدني المحترم (لتفضل بالعلم)
نسخة للملف

المرفى

هاتف : ٤٨٩٥١٥١ (+٩٧٤) فاكس : ٤٣٣٧٧٣٤ (+٩٧٤) ص.ب. ١٩٥٩ - الدوحة - قطر
Tel : (+974) 4895151 - Fax : (+974) 4327734 - P.O.Box : 6959 - Doha - Qatar
البرق الإلكتروني : www.moi.gov.qa Website
E-mail : culfpdqa@moi.gov.qa

PO BOX 15007, AJMAN, UAE
TEL: +97167436665, +971506287115
FAX: +97167437033,
Email: info@vulcanuae.com



PO BOX 117478, DUBAI, UAE
TEL: +97142579811, +971507460465
FAX: +97167437033
Email: info@vulcanuae.com



Qatar Site & Power W.L.L.			
Material Submittal		22 OCT 2009 Rcd	
Client: Qatar Petroleum		Contractor: Qatar Site & Power W.L.L.	
Project Title: EPIC OF TEMPORARY IT DISASTER RECOVERY ROOM AT BLOCK 'C', DUKHAN MANAGEMENT & OPERATIONS BUILDING, DUKHAN		MS No. Rev No.:	034 Rev 00
Contract No: LC 09104500		Date:	20/10/09
To: Community Services Department	Attn: Mr. Mohammed Saifi		
Submittal Details			
As Specified/Alternative: None Specified		Delivery Mode: Land	ETA on Site:
Material Description	Specified	Proposed	Manufac. Name and Address
Fire Rated Steel Door	None Specified	Flush Type	Vulcan Industries LLC P.O. Box 15007 AJMAN UAE Tel: 0097167489874 Fax: 0097167489035
			Supplier
Submitted By: Qatar Site & Power W.L.L.		Discipline: Civil	
QP Comments			
<p>Comments:</p> <p>Door type: FLUSH Vertical section Drawing for both rooms (IT & Generator) should be submitted to clarify the ceiling, raised floor and Door's heights and clearance height for the equipment.</p> <p><i>(Handwritten signature)</i></p> <p><u>N.B.</u> Door height shall be identified as per the clear distance between ceiling and Raised floor.</p> <p><i>(Handwritten signature)</i></p>			
Submittal Status: To be filled by QP (Please tick appropriate box below)			
<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Rejected	Yasser El Maghraby <i>(Signature)</i> QP Sign: <i>(Signature)</i> Date: 25-10-2009	KAMARAZAMAN NORMAN <i>(Signature)</i> QP Sign: <i>(Signature)</i> Date: 25-10-2009	<i>(Signature)</i> QP Sign: <i>(Signature)</i> Date: 25/10
Document No. QSP/QP/MAT/01			
26 OCT 2009			





JUL.08.2009 00:58 4420606

#6603 P.001 /001



Form: FVBM-2
Rev-3, D:11/11/07

QATAR TELECOM (Q-TEL) Q.S.C BUILDING & ENGINEERING SERVICES BUILDING & MAINTENANCE DEPARTMENT

Date : Jan 15, 2009	MATERIAL SUBMITTAL	Submittal No. : 12 of 19 - R1 ALTERNATIVE
PROJECT TITLE	3RD DATA CENTER BUILDING AT WADI SAIL COMPLEX	
CONTRACTOR	NOVATECH BUILDING SYSTEMS W.L.L.	
CONTRACT NO.	GEN-1169/11-2009	
SUB CONTRACTOR		
Material Description	FIRE RATED STEEL DOORS	
B.O.Q. Ref.	BILL NO: 2/3/3	Specs Ref: Sec:17, Part 3, Clause 3.3
Manufacturer:	VULCAN INDUSTRIES L.L.C	Country of Origin: AJMAN - UAE
Supplier Name:	PREMIER ENGG. & TRAD. CO. W.L.L., DOHA	Agent Name:
Literature :	PRE-QUALIFICATION AND TECHNICAL LITERATURE ATTACHED	Sample:
Contractor Signature:		Stamp:
Architectural Comments:		
Name :		
Signature :		
Date :		
Structural Comments :		
Name :		
Signature :		
Date :		
Mechanical Comments :		
Name :		
Signature :		
Date :		15/01/2009
Electrical Comments :		
Name :		
Signature :		
Date :		

Q-TEL Decision :

APPROVED
 APPROVED WITH CONDITIONS
 REJECTED

Date : _____
Signature:

cc: 1. Contractor 2. Q-Tel Project Coordinator



200/1002 #8806 BLDG MAINTN ABU HANOUR #3384 P.001 /002 15/07 2009 11:37 974 4696901

PO BOX 15007, AJMAN, UAE
TEL: +97167436665, +971506287115
FAX: +97167437033,
Email: info@vulcanuae.com



PO BOX 117478, DUBAI, UAE
TEL: +97142579811, +971507460465
FAX: +97167437033
Email: info@vulcanuae.com



RG		MATERIAL SUBMITTAL		ITCC	
Contractor:		Impetal Trading and Contracting Company W.L.L.			
Project No. & Title:		Procurement, Construction and Commissioning of Canters Facilities Expansion		MIN No.: P030/S/ITCG/FMDP/PS-C40/M8228	
Contract No:		CTR/G 11/L 100/07		Date: 23/9/2008	
TO:	RasGas Engineer		Attn:		
Contents:		<input type="checkbox"/> Material (One item only per form) <input type="checkbox"/> Mark-up <input type="checkbox"/> Sample <input type="checkbox"/> Others:			
Discipline:		<input type="checkbox"/> Civil <input type="checkbox"/> Architectural <input type="checkbox"/> Electrical <input type="checkbox"/> Others: <input type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input type="checkbox"/> Plumbing			
Material Description: FIRE RATED STEEL DOOR -					
- Attach all relevant technical literature marked to identify relevant descriptions, current test certificate, samples etc. - Attach a certificate stating compliance with Contract requirements - Highlight any element of contractual non-compliance in this submittal					
Drawing Ref:		D-80-134D-140		Planned date for applicable submittal for:	
Specification Ref:		Arch. Specs. 14		Date:	
BOQ Ref:		Arch Works Item F		1. O & M Manual NA	
Any other Standards Ref:				2. Training Manual & Training NA	
				3. Specified / recommended spare parts: NA	
				4. Warranties and Guarantees NA	
Manufacturer / Supplier					
Company Name:		Vulcan Industries LLC		Country of Origin : UAE	
Address:		PO Box No. 117478 Dubai-UAE		Locally Manufactured: NA	
Local Agent:		PREMIER ENGINEERING PO BOX No. 47251 Deira-Qatar		Production period : NA	
				Total delivery time : NA	
Date required on site :				Contractor Authorized Signature:	
Expected date of arrival on Site :					
RasGas Approval					
<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments (Corrections required)		<input type="checkbox"/> Revise and Resubmit <input type="checkbox"/> Rejected			
Comments:					
APPROVAL IS REQUIRED FOR IRON MONGERY ITEMS.					
CONTRACTOR TO SUBMIT SPECIFIC SAMPLES OF IRON MONGERY WITH CERTIFICATION OF MATERIAL FOR APPROVAL.					
 Engineering Specialist		 Lead / Project Engineer		 Projects Engineering Specialist	
				 Head of Facilities Operations	
Copy to: <input type="checkbox"/> Contractor <input type="checkbox"/> RasGas					
Approval or comments made to the submittal does not relieve the Contractor from their responsibilities. The assessment is to review the general conformance and compliance of the submittal to the contract requirements and specifications.					
FMD-QCF-006, Rev2-Dated 29-05-06					

